

ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: G104332534LCS007 Certificate No: ASTA-TYPE-000636

Applicant: RR Busduct Power Distribution Equipment Manufacturing LLC, Plot No. 597

4904, Warehouse No. 4, Near Pepsi Bottlers, DIP 2, Dubai, U.A.E.

Apparatus: 3200A, TPNHE, $1000V/1000V/8kV (U_e/U_i/U_{imp})$, $50Hz (I_{nA} = 3040A @ 60Hz)$,

double-stack busbar trunking system, with class F epoxy coated tin plated copper busbars with outer layer polyester wrapped in an aluminium enclosure comprising of two flanged ends, two straight lengths and three joint sections.

Manufactured RR Busduct Power Distribution Equipment Manufacturing LLC, Plot No. 597

By: 4904, Warehouse No. 4, Near Pepsi Bottlers, DIP 2, Dubai, U.A.E.

Test Report No: 01060336-7

Designation: RRP320CPHSFLI65 / GUARDEX PLUS

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-6: Edition 1.0 2012-05 Clauses 10.2, 10.3, 10.4, 10.5, 10.9, 10.10, 10.11, 10.12 and Annex BB

Verifications with reference to the tests listed in Annex D of IEC 61439-6: Edition 1.0 2012-05

1: Strength of material and parts 6/7/8: No verification by testing required 2: Degree of protection of enclosures Dielectric properties 9: 3: Clearances 10: Temperature-rise limits 4: Short circuit withstand strength Creepage distances 11: Protection against electric shock and 12: Electromagnetic compatibility (EMC) integrity of protective circuits

Annex BB: Phase conductor characteristics

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.

U K A S
PRODUCT

5th January 2021

Certification Engineer

Certification Officer

Date

010