



Certification Record

CUSTOMER	CLASS	FILE
R R Kabel Limited Survey No. 142/2, Madhuban Dam, Road, Rakholi Silvassa U.T of Dadra & Nagar Haveli 396240 India	5851-01 WIRES-Appliance	246095
Refer to Class Description for program details		

TO THE REQUIREMENTS OF CSA STD C22.2 NO 210-05:

AWM Class	AWM Group	Temp Deg C	Max Volt	Jacket Type Min. Avg. Thick (mm)	Coverings Type Min Avg. Thick (mm)	Size Range AWG Kcmil	Insul. Type Min Avg. Thick (mm)	PVC	Notes
SINGLE CONDUCTOR:									
I	A/B	60,80, 90, 105	30,150, 300,600	-	-	30-25 24-12 11 10-9 8-7 6-3 2 1 1/0-4/0 250 300-350 400-450 500 550-1000 1100-1300	0.78 0.80 0.85 0.90 1.20 1.55 1.60 2.08 2.10 2.45 2.50 2.60 2.65 2.85 3.20		1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3 1,2,3

1400-1750	3.25	1,2,3
-----------	------	-------

1800-2000	3.30	1,2,3
-----------	------	-------

Notes:

1. In all colours except for clear and translucent.
2. Flame rating - FT1.
3. Flame rating - FT2.

/sl

Copyright © 2013 CSA International. All rights reserved.